

August 10, 2006

HUFFCUTT CO., INC.  
BILL OLSON  
4154 123RD ST  
CHIPPEWA FALLS WI 54729

Re: Description: SEWAGE TREATMENT APPARATUS (also see SEWAGE TANKS)  
Manufacturer: HUFFCUTT CO., INC.  
Product Name: BIOMICROBICS MICRO FAST .9 and 0.75  
Model Number(s): 750/1250 L.L. 42.25"  
Product File No: 20060372

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of August 2011.

This approval supercedes the approval issued on October 16, 2000, under product file number 20000257.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20000257.

This approval is contingent upon compliance with the following stipulation(s):

- **A copy of a successful water tightness test report for the product approved under this product file number in the regarding block must be submitted to this office prior to this product being sold for installation in Wisconsin.**
- This tank may only be used when installed with the Bio-Microbics, Inc., High Strength or Micro Fast sewage treatment apparatus.
- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- This product must be installed in accordance with the manufacturer's printed instructions, product approval and the plan approval. If there is a conflict between the manufacturer's instructions and the plan approval, the plan approval will take precedence.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE  
Plumbing Product Reviewer  
phone: 608-266-6742  
fax: 608-267-9566  
e-mail: mike.beckwith@wisconsin.gov